



ADDENDUM #1

June 29, 2016

CDBG PY15-001 **Prescott Boys and Girls Club** *Outdoor Basketball Court*

PREPARED BY:

CITY OF PRESCOTT, ARIZONA

Community Development, CDBG Program Administration

928-777-1143

BID DUE DATE:

July 7, 2016, 2:00 p.m.

A. Pre-Bid Conference

The pre-bid conference and walk-through was held at the Boys and Girls Club at 335 East Aubrey Street, Prescott, AZ 86303 at 1:00 pm on June 27, 2016.

1. Question: Is 4" of concrete sufficient?

Answer: 4" CONCRETE WILL BE SUFFICIENT.

2. Question: Can you clarify slopes or finished grade?

Answer: SUBGRADE WORK WILL BE PROVIDED BY OTHERS + OR – 2 TENTHS OF ONE FOOT.

3. Question: How can ADA requirements be met with the driveway?

Answer: ADA REQUIREMENTS MUST BE MET IN PROJECT FOOTPRINT ONLY. OTHER REQUIRED FIXES WILL BE HANDLED AT A LATER DATE.

4. Question: Will contractor be required to survey?

Answer: SURVEY TO BE PROVIDED BY OTHERS.

5. Question: What permits are required?

Answer: GRADING PERMIT WILL BE SECURED BY OTHERS. ALL OTHER PERMITS WILL BE THE RESPONSIBILITY OF THE CONTRACTOR.

6. Question: Concrete color? PSI? Maximum slump? Finish?

Answer: GREY CONCRETE / 4000 PSI / 4" SLUMP + OR – 1 / WELDED WIRE FABRIC 6.6X6.6 / MEDIUM BROOM FINISH.

7. Question: Saw cut layout?

Answer: SAW CUT PATTERN WILL BE DETERMINED IN THE FIELD. JOINTS CAN BE LEFT OPEN.

8. Question: Is a bid bond required?

Answer: NO

9. Question: Can we disregard the contingency, staking and earthwork line items on the bid form?

Answer: YES

B. Clarifications

1. Please note that the primary contractor will need to be registered in the federal System of Award Management (SAM) system. Questions can be directed to isabel.rollins@nacog.org.
2. As noted on the bid form, we ask that bids are good for 60 days after submission. We expect to award the contract at the August 9, 2016 City Council meeting.

C. Acknowledgement

- a. Please remember to acknowledge addenda number(s) on "Bid Form A – Bidder Response Cover Sheet" (Page 17).