



**ADDENDUM NUMBER TWO
to the
PROJECT SPECIFICATIONS
and
CONTRACT DOCUMENTS
for
SR89 White Spar Waterline Relocation
(CIP # 7007810-13101)**

DATE OF ADDENDUM: September 14, 2012

TO ALL BIDDERS BIDDING ON THE ABOVE PROJECT:

In accordance with the INFORMATION FOR BIDDERS, Addenda, page 8, the following Addendum shall be made part of the Contract Documents. All other provisions of the Contract Documents remain unchanged. The Bidder shall acknowledge receipt of this addendum on page 13 of the Proposal by inserting the addendum number and date on the executed page of the Proposal. The contents of this Addendum shall be given full consideration in the preparation of the Bid.

ORIGINAL BID OPENING: August 23, 2012 at 2:00 p.m., MST

FIRST AMENDED BID OPENING: September 20, 2012 at 2:00 p.m., MST

SECOND AMENDED BID OPENING: November 15, 2012 at 2:00 p.m., MST

Project Specifications

1. Page 9, Bid Schedule shall be deleted and replaced in its entirety with "**REVISED BID SCHEDULE**," see attached Page 9.
2. Page 18, Contract, Article X – Liquidated Damages, all references to the amount of liquidated damages shall be revised to \$570.00 per calendar day.
3. Page 22, Public Notice, Item (A), Insert "SR89 White Spar Waterline Relocation" in the first line as the project name.

Technical Specification

1. Page 29, is inserted incorrectly between pages 12 and 13.
2. Page 59, Section 610-11D, Private Water Service Line Reconnection, subsection (1) that reads:
"Sweat fittings will not be allowed" shall be replaced with

"Sweat fittings are acceptable in the construction of the backflow preventers. The CONTRACTOR shall install union fittings on the vertical riser per standard detail 3-21AP."

Special Provisions

1. Page 6, Section 400-1 Temporary Traffic Control, subsection (H)(2) shall be revised to read "The Bid Schedule includes an allowance for Off Duty Police Officers for the purpose of encumbering funds to cover the cost of Off Duty Police Officers. The amount of the allowance is determined by the Public Works Director and is not subject to individual bid pricing. All bidders shall incorporate the amount in the bid schedule and shall reflect the same in the total bid for this project.

It shall be understood that this allowance is an estimate only. The allowance shall not be used without approval of the Public Works Director.

Reimbursement for Off Duty Police Officers shall be based on actual cost, plus an allowable markup to the prime contractor of 15%, for use of Off Duty Police Officers approved by the Public Works Director.

2. Page 8, Section 610-2 Temporary Water Main Piping shall be modified to add a subsection (N) that shall read "Schedule 40 PVC will be an acceptable material for temporary services connected to the temporary water main. The services and the temporary water main shall be protected from damage from traffic and from potential freezing temperatures and shall comply with Section 610 and the Special Provisions"
3. Page 8, Section 610-2 Temporary Water Main Piping shall be modified to add a subsection (O) that shall read "Fire hydrants are not required on the temporary water main. Fire hydrants that are taken out of service shall be covered with a bag to be easily recognized as being out of service until they are removed or until they are brought back into service. The CONTRACTOR shall notify the local Fire Marshal of any fire hydrants that will be taken out of service."

Drawings

Drawings P01, P02, P03, P04, and P05, construction note no.1 shall be revised to include the text "(restrained)."

- END -

City of Prescott, Public Works Department



Mark Nietupski, Public Works Director



Acknowledgement: (must be signed and turned in with the bid documents)

Company Name

Date

Signature of Company Official

Date

REVISED BID SCHEDULE
SR89-White Spar Waterline Replacement

Item #	Item Description	Unit	Quantity	Unit Price	Amount
104-3	Mobilization	LS	1		
105-8	Construction Staking	LS	1		
105-9	As-built Preparation and Coordination	LS	1		
107-1	Storm Water Pollution Prevention Plan	LS	1		
109-1	Contract Allowance	ALLOW	1	\$60,000.00	\$60,000.00
336-1a	Temporary Pavement & Trench Detail, Type A, Detail 1	SY	668		
400-1a	Traffic Control Plan & Devices	LS	1		
400-1b	Off-Duty Police Officers	ALLOW	1	\$30,000.00	\$30,000.00
601-2	Rock Removal (Trench)	CY	300		
610-1a	4-inch Waterline (DIP CL 350)	LF	17		
610-1b	6-inch Waterline (DIP CL 350)	LF	17		
610-1c	8-inch Waterline (DIP CL 350)	LF	440		
610-1d	12-inch Waterline (DIP CL 350)	LF	2053		
610-2	Temporary Waterlines, Valves, and Appurtenances	LS	1		
610-9a	Furnish and Install Fire Hydrant Assembly	EA	6		
610-11a	1-inch Copper Water Service, COP Std Det 3-16P & 3-21AP	EA	8		
610-11b	2-inch Copper Water Service, COP Std Det 3-16AP & 3-21AP	EA	1		
610-20	Concrete Encasement	LF	125		
610-40a	Remove Existing Waterline, Valves, Fire Hydrants, Water Services and Appurtenances	LS	1		
630-3a	4-inch Gate Valve, Box, & Cover	EA	1		
630-3b	8-inch Gate Valve, Box, & Cover	EA	8		
630-3c	12-inch Gate Valve, Box, & Cover	EA	4		
630-4	8-inch Tapping Sleeve, Valve, Box, and Cover	EA	1		
630-6a	Air/Vacuum Release Valve Assembly	EA	4		
630-6b	Blow - Off Assembly	EA	4		
	TOTAL				

Total Base Bid:

_____ Dollars
 (Written Words)

 Signature of Company Official

 Title

 Company Name

 Phone Number

 Address

 Fax Number

 City/State

 Zip Code