

## ADDENDUM NUMBER THREE

to the

### Request for Multi-Step Sealed Bids for the Design and Construction of the Sundog WWTP Dewatering Building Replacement Project

DATE OF ADDENDUM NO. 3: February 27, 2015

#### TO ALL BIDDERS BIDDING ON THE ABOVE PROJECT:

The following addendum shall be made part of the Contract Documents. All other provisions of the Contract Documents remain unchanged. The Bidder shall acknowledge receipt of this addendum on page 2 of the Proposal by inserting the addendum number and date on the executed page of the Proposal. The contents of this Addendum shall be given full consideration in the preparation of the Bid.

#### ADDENDUM:

Add Under Section 1.2, Part A.iib

b. Heating and ventilation system. To meet NFPA requirements the building will need a supply and exhaust fan. The supply and exhaust fans are required to have the ability for 6 air changes per hour.

#### CLARIFICATIONS

1. It is indicated the project is to be completed 60 days after award. Are you looking for the construction to be completed or the project ready for construction? The RFP also states that preliminary documents are to be completed within 21 days. There is also a requirement of 3 weeks review time for each phase of design. Can we get a clarification of what is expected schedule wise or are you expecting us to prepare a schedule.


The project timeframe will include 30 days for a final design including a one week timeframe for City staff review. The construction schedule will be 60 days. City staff will work with the selected contractor on the preparation of the project overall schedule. The project is to be completed within 100 calendar days.

2. The RFQ is requesting drawings, product data sheets or shop drawings as part of the submittal. There needs to be some degree of completed design to assemble these items. What are you looking for as part of the Phase I submittal?

The requirements of Section 3, Un-priced Technical Proposal Format is intended to include your company's means and methods to complete the project including general components of the structure, detailed architectural renderings including rough dimensions (north, south, east, west views including door locations), materials submittals from comparable projects, and potential innovative ideas.

- END -

City of Prescott, Public Works Department

  
Henry Hash, Public Works Director

2-26-15

**Acknowledgement:** (must be signed and turned in with the bid documents)

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature of Company Official

\_\_\_\_\_  
Date