



PUBLIC OUTREACH SUMMARY

Pressure Zone 19 Utility Improvement Project
Public Meeting #1

June 2, 2010

This packet includes:

- Community Meeting Summary
- Community Meeting Flier
- Community Meeting PowerPoint Presentation

**City of Prescott Pressure Zone 19
Utility Improvement Project
Community Meeting # 1 Summary**

On May 20, 2010, the City of Prescott held a public meeting for residents of Pressure Zone 19 Utility Improvement project area, as part of an ongoing public involvement initiative associated with the project. City staff made outreach efforts to area residents and property owners to address project-related questions and gather public input. Outreach efforts included a press release for local radio and newspaper coverage and a bulk mailing of 1,300 fliers to area residents within the project area. Eleven people signed in to the meeting, with several anonymous members of the public in attendance. Approximately a dozen questions were asked during the question and answer session with City staff. Two people submitted comments at the meeting.

All of the questions focused on the availability of water for residence from the water main extension. A few residences from Mullen Way and Wickwood Lane area wanted to know if they could connect to the new water line and if a water line could be constructed on Mullen Way to service area residence. Staff stated an 8-inch water line stub-out would be installed off the main into Mullen Way for the connection of a future water line, but that residences would be responsible for an improvement district for design and construction of any future water line. Anyone connecting to the water system would be required to pay all appropriate impact fees and would be required to obtain a permit from the City for the connection. Additionally, for some residences the pressure may not be high enough to supply water and a pump system or hydro-pneumatic tank may be required for individual systems.

No questions or concerns were raised about the proposed alignment of the water main or water storage reservoir. Staff did mention that subsequent meetings will be held once the design process has been further completed. Attached is a copy of the signup sheet, and comment cards that were submitted from the meeting.