City of Prescott

Kitchen Hood Ductwork Light Test

Test shall be conducted after dark on all portions of ductwork that is outside.
Entire ductwork shall be checked from hood flange to top of stack.

A form will be required for each individual duct.

***** Test shall be conducted in one of these conditions: *****

½ hour after sunset, ½ hour before sunrise, or the room shall be in total darkness

Address (location of test): _____

Time of Test _____AM/PM Date of test _____

Was the test conducted both inside and outside of the building? ☐ YES ☐ NO

Size of Light Used _____ Watts

Test was performed by: _____
Company Name

Contractor's License Number: _____

Testing Representative's Name: _____
(Please Print Tester's Name)

Signature of Testing Representative: _____

Was the welding on the hood and shaft performed by a certified welder? ☐ YES ☐ NO
If ***NO***, a special inspection will be ***required***.

Welding Company's Name: _____

Welder's Name: _____
(Please Print Welder's Name)

Welder's Signature: _____
(Welder's Signature)

Welder's Certification Number: _____ Date Updated: _____

JUNE 2008